



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA182925

**Certificate Holder:** SolaX Power Network Technology (Zhejiang) Co., Ltd  
No. 288 Shizhu Road,  
Tonglu Economic Development Zone,  
Dongxing District 311500, Tonglu City,  
Zhejiang Province  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** PV Grid-connected Inverter

**Brand Name:**



**Model No.:**

X3-15.OP-T-D

**Markings:**

Input: 1000Vdc Max, MPP voltage range 160-950Vdc,  
10/20A, Isc 12/24A  
Grid: 3/N/PE 230/400V~ 50/60Hz, 3x23.8A 15000VA  
IP65, Class I

**Standard:**

IEC 62109-1 Ed 1.0  
IEC 62109-2 Ed 1.0  
AS/NZS 4777.2:2015

**Conditions:**

Nil

**Certification Mark:** SAA182925 or RCM

**Date First Registered:** 17 October 2018

**Date of Expiry:** 17 October 2023


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 17-10-18 182925/1