



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA182925

Date of Issue: 17 October 2018

Class Description: Non-Declared

Product Description: PV Grid-connected Inverter

Additional Models:

The following models are similar to X3-15.OP-T-D except are rated:

X3-12.OP-T-D	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz, 3x19.2A 12000VA
X3-10.OP-T-D	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x16A 10000VA
X3-8.OP-T-D	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x12.8A 8000VA

The following models are similar to X3-15.OP-T-D except without DC switch and are rated:

X3-15.OP-T-N	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x23.8A 15000VA
X3-12.OP-T-N	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x19.2A 12000VA
X3-10.OP-T-N	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x16A 10000VA
X3-8.OP-T-N	Input: 1000Vdc Max, MPP voltage range 160-950Vdc, 10/20A, Isc 12/24A Grid: 3/N/PE 230/400V~ 50/60Hz 3x12.8A 8000VA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 17-10-18 182925/2